

Type Report

Report Date: 17/11/2021

SIM2I000101 Integriti Zone Mapping - SIMII

Type No	Description	Action Plan
100	Medical Emergency	Medical Alarm
101	Pendant Emergency	Panic Alarm
102	Deadman Emergency	Panic Alarm
110	Fire Alarm	Fire Alarm
111	Smoke Alarm	Fire Alarm
112	Act Combustion	Fire Alarm
113	Fire Water Flow	Fire Alarm
114	Fire Heat	Fire Alarm
115	Fire Pull Station	Fire Alarm
116	Fire Duct	Fire Alarm
117	Fire Flame	Fire Alarm
118	Fire Near Flame	Fire Alarm
120	Panic Alarm	Panic Alarm
121	Duress Alarm	Panic Alarm
122	Terminal Duress	Panic Alarm
123	Audible	General Alarm
124	Duress Access Grant	General Alarm
125	Duress Egress Grant	General Alarm
130	Burglary	Intruder Alarm
131	Burglary Perimeter	Intruder Alarm
132	Burglary Interior	Intruder Alarm
133	24 Hour	Intruder Alarm
134	Entry / Exit Burglary	Intruder Alarm
135	Day / Night Burglary	Intruder Alarm
136	Burglary Outdoor	Intruder Alarm
137	Tamper	Intruder Alarm
138	Burglary Near Alarm	Intruder Alarm
139	Intrusion Verifier	Intruder Alarm
140	General Alarm	General Alarm
141	Polling Loop Open	System Alarm
142	Polling Loop Short	System Alarm
143	LAN Communicator	Polling Failure
144	Sensor Tamper	Intruder Alarm
145	Expansion Module Tmp	System Alarm
146	Silent Burglary	Intruder Alarm
147	Sensor Superv Fail	Intruder Alarm
150	24 Hour Aux	System Alarm

151	Gas Detected	Environmental Alarm
152	Refrigeration	Environmental Alarm
153	Loss of heat	Environmental Alarm
154	Water leakage	Environmental Alarm
155	Foil break alarm	Environmental Alarm
156	Day trouble alarm	Environmental Alarm
157	Low gas level	Environmental Alarm
158	High Temperature	Environmental Alarm
159	Low temperature	Environmental Alarm
161	Loss of air flow	Environmental Alarm
162	Carbon Mono. Detect	Environmental Alarm
163	Tank Level	Environmental Alarm
200	Fire Supervisory	Fire Alarm
201	SPV - Water P. Low	Environmental Alarm
202	SPV - Low CO2	Environmental Alarm
203	SPV - Gate Valve	Environmental Alarm
204	SPV - Water LV Low	Environmental Alarm
205	SPV - Pump Active	Environmental Alarm
206	SPV Pump Fail	Environmental Alarm
300	System Trouble	System Alarm
301	Ac Loss	A/C Failure
302	Low System Battery	Low Battery
303	Bad Ram Checksum	System Alert
304	Bad Rom Checksum	System Alert
305	System Reset	System Alert
306	Program Altered	System Alert
307	Zone Self Test	System Alert
308	System Shutdown	System Alert
309	Battery Test Fail	System Alert
310	Ground Fault	A/C Failure
311	Batt. Missing/Dead	Low Battery
312	PWR Sply Ovrcurrnt	A/C Failure
313	Engineer Reset	Zone Info, No Alarm
314	Primary Power Supply Failure	A/C Failure
316	System Tamper	General Alarm
320	Siren/Output Trouble	System Alert
321	Bell/Siren 1 Trouble	System Alert
322	Bell/Siren 2 Trouble	System Alert
323	Alarm Relay	System Alarm
324	Relay Trouble	System Alert
325	Reversing Trbl	System Alert
326	Notif. Applnce Ckt#3	System Alert
327	Notif. Applnce CKT#4	System Alert
330	System Peripheral	System Alert
331	Sys Polling open	System Alert
332	Sys Polling Shut	System Alert
333	Expansion Module Fai	System Alert

334	Repeater Fail	System Alert
335	Printer Out Of Paper	System Alert
336	Local Printer Fail	System Alert
337	Exp. Mod DC Loss	A/C Failure
338	Exp. Mod Low Bat	Low Battery
339	Exp. Mod Reset	System Alert
341	Exp. Mod Tamper	General Alarm
342	Trbl Poll LP Sht	System Alert
343	Trbl Exp. Mod Trb	System Alert
344	RF Recv jam detect	System Alert
345	AES Encryption Trouble	System Alert
350	Communications Fail	Polling Failure
351	Phone Line Fault	System Alarm
352	Telco 2 Fault	System Alert
353	Lr Radio Fault	System Alarm
354	Dialer Fault	Polling Failure
355	Loss Radio Sprv	System Alert
356	Loss Central Plg	System Alert
357	Radio VSWR probm	System Alert
370	Protect. LP Trbl	System Alert
371	Protect. LP Open	System Alert
372	Protect. LP shrt	System Alert
373	Fire Trouble	System Alarm
374	Exit ER by zone	System Alert
375	Panic zone trbl	Panic Alarm
376	Holdup Zone Trbl	Intruder Alarm
377	Swinger Trbl	System Alarm
378	Cross Zone Trbl	System Alert
380	Sensor TR Sy/N Z	System Alert
381	Supervsn loss RF	Polling Failure
382	Sensor Trouble	System Alert
383	Sensor Tamper	General Alarm
384	RF Tran Low Bat	Low Battery
385	Smoke Det. Hi Sen	System Alert
386	Smoke Det. Lo Sen	System Alert
387	Intrs Det. Hi Sen	System Alert
388	Intrs Det. Lo Sen	System Alert
389	Sensor Slf-Tst Fail	System Alert
391	Sensor Watch Trbl	System Alert
392	Drift Compens. Error	System Alert
393	Maintenance Alert	System Alert
400	Open	Opening (Unset), No Alarm
401	Open By	Opening (Unset), No Alarm
402	DISARMED	Opening (Unset), No Alarm
403	Open Auto	Opening (Unset), No Alarm
404	Late Closing	Late to Close
405	Deferred O/C	Access Alarm

406	Cancel by user	Access Alarm
407	Remote Open	Opening (Unset), No Alarm
408	Quick Open	Opening (Unset), No Alarm
409	Keyswitch Open	Opening (Unset), No Alarm
410	Remote Program Alter	Zone Info, No Alarm
411	Call back Req.	System Alert
412	Successful Access	Zone Info, No Alarm
413	Unsuccessful Access	Zone Info, No Alarm
414	System Shutdown	System Alert
415	Dialer Shutdown	System Alert
416	Successful Upload	Zone Info, No Alarm
420	Door Forced Ajar	Access Alarm
421	Access Denied	Access Alarm
422	Access RPT/user	Zone Info, No Alarm
423	Forced Access	Access Alarm
424	Access Denied	Zone Info, No Alarm
425	Egress Granted	Zone Info, No Alarm
426	Access Door Propped	Access Alarm
427	Accss Door Stat. Trb	System Alert
428	Accss Exit Rqst Trb	System Alert
430	Access PRogram Exit	System Alert
431	Access Level Change	Zone Info, No Alarm
432	Accss Rly/Trgr Fail	Access Alarm
433	Access Rte Shunt	Access Alarm
434	Access Dsm Shunt	Access Alarm
435	Second Person Access	Closing (Set), No Alarm
436	Irregular Access	Closing (Set), No Alarm
441	Op/CL-Stay mode	Zone Info, No Alarm
442	Keyswitch Armd Stay	Zone Info, No Alarm
450	Exception O/C	General Alarm
451	Early O/C	Access Alarm
452	Late O/C	Late to Close
453	Fail to Open	Access Alarm
454	Fail To Close	Late to Close
455	Auto-Arm Fail	System Alert
456	Partial O/C	System Alert
457	Exit ER by User	Zone Info, No Alarm
458	User on Premise	General Alarm
459	Recent O/C	Zone Info, No Alarm
461	Wrong Code Entry	Zone Info, No Alarm
462	Legal Code Entry	Zone Info, No Alarm
463	RE-Arm After Alarm	Closing (Set), No Alarm
464	Auto-Arm Time Extnd	System Alert
465	Panic Alarm Reset	Panic Alarm
466	Srvce on/off Prmiss	System Alert
500	System Disable	System Alert
501	Access Reader Disable	System Alert

502	System Disable	System Alert
503	System Disable	System Alert
504	System Disable	System Alert
505	System Disable	System Alert
506	System Disable	System Alert
507	System Disable	System Alert
508	System Disable	System Alert
509	System Disable	System Alert
510	System Disable	System Alert
520	Sndr/Rly Disable	System Alert
521	Bell 1 Disable	System Alert
522	Bell 2 Disable	System Alert
523	Alrm Rly Disable	System Alert
524	Trbl Rly Disable	System Alert
525	RVSG Rly Disable	System Alert
526	Notif. Applnce CKT #3	System Alert
527	Notif. Applnce CKT#4	System Alert
530	Periphrl Disable	System Alert
531	Module Added Periphrl Disable	System Alert
532	Module Removed Periphrl Disable	System Alert
533	Periphrl Disable	System Alert
534	Periphrl Disable	System Alert
535	Periphrl Disable	System Alert
536	Periphrl Disable	System Alert
537	Periphrl Disable	System Alert
538	Periphrl Disable	System Alert
539	Periphrl Disable	System Alert
540	Periphrl Disable	System Alert
551	Dialer Disable	System Alarm
552	Radio TX Disable	System Alarm
553	Remote Up/Dnw Disbl	System Alert
570	Zone Bypass	Zone Bypass
571	Fire Bypass	Zone Bypass
572	24 Hour Zone Bypass	Zone Bypass
573	Burglary Bypass	Zone Bypass
574	Group Bypass	Zone Bypass
575	Swinger Bypass	Zone Bypass
576	Access Zone Shunt	Zone Bypass
577	Access Pint Bypass	Zone Bypass
601	Manual Test	Test Report
602	Periodic Test	Test Report
603	Periodic RF XMN	Test Report
604	Fire Test	General Alarm
605	Status RPT Next	Zone Info, No Alarm
606	Listen in next	Zone Info, No Alarm
607	Walk Test Mode	Zone Info, No Alarm
608	Sys Trbl PResent	System Alarm

609	Video TX Active	Zone Info, No Alarm
611	Point Tested OK	Zone Info, No Alarm
612	Point not Tested	System Alert
613	Intrsn ZE Wlk Tested	Zone Info, No Alarm
614	Fire ZN Walk Tested	System Alert
615	Panic ZN Walk Tested	System Alert
616	Service Request	System Alert
621	Event Log Reset	System Alert
622	Eventlg 50% Full	System Alert
623	Eventlg 90% Full	System Alarm
624	Eventlg Ovrflow	System Alarm
625	Time-Date Reset	System Alert
626	Time-Date Wrong	System Alert
627	Progr Mode Entry	System Alert
628	Progr Mode Exit	Zone Info, No Alarm
629	32HrR Evnt Log Mrkr	System Alert
630	Schedule Changed	Zone Info, No Alarm
631	Exception Sched. Change	Zone Info, No Alarm
632	Accss Schd Chnge	Zone Info, No Alarm
641	Senior Wtch Trbl	System Alarm
642	Latchkey Sprvsn	System Alert
651	Reserved Adempco	Intruder Alarm
652	Reserved Adempco	Intruder Alarm
653	Reserved Adempco	Intruder Alarm
654	System Inactivity	System Alert
688	Periodic test	Test Report
689	Raid Alarm	Panic Alarm
1000	Restore Zone	Restoral, No Alarm
1100	Restore Medical	Restoral, No Alarm
1101	Restore Pendant tran	Restoral, No Alarm
1102	Restore Fail To Rprt	Restoral, No Alarm
1110	Restore Fire Alarm	Restoral, No Alarm
1111	Restore Smoke Alarm	Restoral, No Alarm
1112	Restore Act Combusti	Restoral, No Alarm
1113	Restore Fire Water Flow	Restoral, No Alarm
1114	Restore Fire Heat	Restoral, No Alarm
1115	Fire Pull Station Restore	Restoral, No Alarm
1116	Restore Fire Duct	Restoral, No Alarm
1117	Restore Fire Flame	Restoral, No Alarm
1118	Restore Fire Near Flame	Restoral, No Alarm
1120	Panic restore	Restoral, No Alarm
1121	Restore Duress Alarm	Restoral, No Alarm
1122	Restore Terminal Duress	Restoral, No Alarm
1123	Restore Audible	Restoral, No Alarm
1124	Restore Duress Access Grant	Restoral, No Alarm
1125	Restore Duress Egress Grant	Restoral, No Alarm
1130	Restore Zone	Restoral, No Alarm

1131	Restore Burglary Perimeter	Restoral, No Alarm
1132	Restore Burglary Interior	Restoral, No Alarm
1133	Restore 24H	Restoral, No Alarm
1134	Restore Entry / Exit Burglary	Restoral, No Alarm
1135	Restore Day / Night Burglary	Restoral, No Alarm
1136	Restore Burglary Out	Restoral, No Alarm
1137	Restore Tamper	Restoral, No Alarm
1138	Restore Burglary Near Alarm	Restoral, No Alarm
1139	Restore Intrusion Verifier	Restoral, No Alarm
1140	Restore Zone	Restoral, No Alarm
1141	Restore Polling Loop Open	Restoral, No Alarm
1142	Restore Polling Loop Short	Restoral, No Alarm
1143	Restore LAN Communicator	Restoral, No Alarm
1144	Restore Sensor Tamp	Restoral, No Alarm
1145	Restore	Restoral, No Alarm
1146	Restore Silent Burglary	Restoral, No Alarm
1147	Restore Sensor Superv Fail	Restoral, No Alarm
1150	Restore 24 Hour Aux	Restoral, No Alarm
1151	Restore Gas Detected	Restoral, No Alarm
1152	Restore Refrigeration	Restoral, No Alarm
1153	Restore Loss of heat	Restoral, No Alarm
1154	Restore Water leakage	Restoral, No Alarm
1155	Restore Foil break alarm	Restoral, No Alarm
1156	Restore Day trouble alarm	Restoral, No Alarm
1157	Restore Low gas level	Restoral, No Alarm
1158	Restore High Temperature	Restoral, No Alarm
1159	Restore Low temperature	Restoral, No Alarm
1161	Restore Loss of air flow	Restoral, No Alarm
1162	Restore Carbon Mono. Detect	Restoral, No Alarm
1163	Restore Tank Level	Restoral, No Alarm
1200	Restore Fire Supervisory	Restoral, No Alarm
1201	Restore SPV - Water P. Low	Restoral, No Alarm
1202	Restore SPV - Low C02	Restoral, No Alarm
1203	Restore SPV - Gate Valve	Restoral, No Alarm
1204	Restore SPV - Water LV Low	Restoral, No Alarm
1205	Restore SPV - Pump Active	Restoral, No Alarm
1206	Restore SPV Pump Fail	Restoral, No Alarm
1300	Restore Sys Trouble	Restoral, No Alarm
1301	Restore Ac Fail	Restoral, No Alarm
1302	Restore Low Sys Batt	Restoral, No Alarm
1303	Restore Bad Ram Checksum	Restoral, No Alarm
1304	Restore Bad Rom Checksum	Restoral, No Alarm
1305	Restore System Reset	Restoral, No Alarm
1306	Restore Program Altered	Restoral, No Alarm
1307	Restore Zone Self Test	Restoral, No Alarm
1308	Restore System Shutdown	Restoral, No Alarm
1309	Restore Battery Test Fail	Restoral, No Alarm

1310	Restore Ground Fault	Restoral, No Alarm
1311	Restore Batt. Missing/Dead	Restoral, No Alarm
1312	Restore PWR Sply Ovrcurrnt	Restoral, No Alarm
1313	Restore Engineer Reset	Restoral, No Alarm
1314	Restore Primary Power Supply Failure	Restoral, No Alarm
1316	Restore System Tamper	Restoral, No Alarm
1320	Restore Siren/Output Trouble	Restoral, No Alarm
1321	Restore Bell/Siren	Restoral, No Alarm
1322	Restore Bell/Siren 2 Trouble	Restoral, No Alarm
1323	Restore Alarm Relay	Restoral, No Alarm
1324	Restore Relay Trouble	Restoral, No Alarm
1325	Restore Reversing Trbl	Restoral, No Alarm
1326	Restore Notif. Applnce Ckt#3	Restoral, No Alarm
1327	Restore Notif. Applnce CKT#4	Restoral, No Alarm
1330	Restore System Peripheral	Restoral, No Alarm
1331	Restore Sys Polling open	Restoral, No Alarm
1332	Restore Sys Polling Shut	Restoral, No Alarm
1333	Restore Expansion Module Fai	Restoral, No Alarm
1334	Restore Repeater Fail	Restoral, No Alarm
1335	Restore Printer Out Of Paper	Restoral, No Alarm
1336	Restore Local Printer Fail	Restoral, No Alarm
1337	Restore Exp. Mod DC Loss	Restoral, No Alarm
1338	Restore Exp. Mod Low Bat	Restoral, No Alarm
1339	Restore Exp. Mod Reset	Restoral, No Alarm
1341	Restore Exp. Mod Tamper	Restoral, No Alarm
1342	Restore Trbl Poll LP Sht	Restoral, No Alarm
1343	Restore Trbl Exp. Mod Trb	Restoral, No Alarm
1344	Restore RF Recv jam detect	Restoral, No Alarm
1345	Restore AES Encryption Trouble	Restoral, No Alarm
1350	Restore Communications Fail	Restoral, No Alarm
1351	Restore Phone Line Fault	Restoral, No Alarm
1352	Restore Telco 2 Fault	Restoral, No Alarm
1353	Restore Lr Radio Fault	Restoral, No Alarm
1354	Restore Dialer Fault	Restoral, No Alarm
1355	Restore Loss Radio Sprv	Restoral, No Alarm
1356	Restore Loss Central Plg	Restoral, No Alarm
1357	Restore Radio VSWR probm	Restoral, No Alarm
1370	Restore Protect. LP Trbl	Restoral, No Alarm
1371	Restore Protect. LP Open	Restoral, No Alarm
1372	Restore Protect. LP shrt	Restoral, No Alarm
1373	Restore Fire Trouble	Restoral, No Alarm
1374	Restore Exit ER by zone	Restoral, No Alarm
1375	Restore Panic zone trbl	Restoral, No Alarm
1376	Restore Holdup Zone Trbl	Restoral, No Alarm
1377	Restore Swinger Trbl	Restoral, No Alarm
1378	Restore Cross Zone Trbl	Restoral, No Alarm
1380	Restore Sensor TR Sy/N Z	Restoral, No Alarm

1381	Restore Supervsn loss RF	Restoral, No Alarm
1382	Restore Sensor Trouble	Restoral, No Alarm
1383	Restore Sensor Tamp	Restoral, No Alarm
1384	Restore RF Tran Low Bat	Restoral, No Alarm
1385	Restore Smoke Det. Hi Sen	Restoral, No Alarm
1386	Restore Smoke Det. Lo Sen	Restoral, No Alarm
1387	Restore Intrs Det. Hi Sen	Restoral, No Alarm
1388	Restore Intrs Det. Lo Sen	Restoral, No Alarm
1389	Restore Sensor Slf-Tst Fail	Restoral, No Alarm
1391	Restore Sensor Watch Trbl	Restoral, No Alarm
1392	Restore Drift Compens. Error	Restoral, No Alarm
1393	Restore Maintenance Alert	Restoral, No Alarm
1400	Close By	Closing (Set), No Alarm
1401	Close By	Closing (Set), No Alarm
1402	ARMED	Closing (Set), No Alarm
1403	Close Auto	Closing (Set), No Alarm
1404	Restore Late Closing	Restoral, No Alarm
1405	Restore Deferred O/C	Restoral, No Alarm
1406	Restore Cancel by user	Restoral, No Alarm
1407	Remote Close	Closing (Set), No Alarm
1408	Quick Close	Closing (Set), No Alarm
1409	Keyswitch Close	Closing (Set), No Alarm
1410	Restore Remote Program Alter	Restoral, No Alarm
1411	Restore Call back Req.	Restoral, No Alarm
1412	Restore Successful Access	Restoral, No Alarm
1413	Restore Unsuccesful Access	Restoral, No Alarm
1414	Restore System Shutdown	Restoral, No Alarm
1415	Restore Dialer Shutdown	Restoral, No Alarm
1416	Restore Successful Upload	Restoral, No Alarm
1420	Restore Door Forced Ajar	Restoral, No Alarm
1421	Restore Access Denied	Restoral, No Alarm
1422	Restore Access RPT/user	Restoral, No Alarm
1423	Restore Forced Access	Restoral, No Alarm
1424	Restore Access Denied	Restoral, No Alarm
1425	Restore Egress Granted	Restoral, No Alarm
1426	Restore Access Door Propped	Restoral, No Alarm
1427	Restore Accss Door Stat. Trb	Restoral, No Alarm
1428	Restore Accss Exit Rqst Trb	Restoral, No Alarm
1430	Restore Access PProgram Exit	Restoral, No Alarm
1431	Restore Access Level Change	Restoral, No Alarm
1432	Restore Accss Rly/Trgr Fail	Restoral, No Alarm
1433	Restore Access Rte Shunt	Restoral, No Alarm
1434	Restore Access Dsm Shunt	Restoral, No Alarm
1435	Restore Second Person Access	Restoral, No Alarm
1436	Restore Irregular Access	Restoral, No Alarm
1441	Restore Op/CL-Stay mode	Restoral, No Alarm
1442	Restore Keyswitch Armd Stay	Restoral, No Alarm

1450	Restore Exception O/C	Restoral, No Alarm
1451	Restore Early O/C	Restoral, No Alarm
1452	Restore Late O/C	Restoral, No Alarm
1453	Restore Fail to Open	Restoral, No Alarm
1454	Restore Fail To Close	Restoral, No Alarm
1455	Restore Auto-Arm Fail	Restoral, No Alarm
1456	Restore Partial O/C	Restoral, No Alarm
1457	Restore Exit ER by User	Restoral, No Alarm
1458	Restore User on Premiss	Restoral, No Alarm
1459	Restore Recent O/C	Restoral, No Alarm
1461	Restore Wrong Code Entry	Restoral, No Alarm
1462	Restore Legal Code Entry	Restoral, No Alarm
1463	Restore RE-Arm After Alarm	Restoral, No Alarm
1464	Restore Auto-Arm Time Extnd	Restoral, No Alarm
1465	Restore Panic Alarm Reset	Restoral, No Alarm
1466	Restore Srvce on/off Prmiss	Restoral, No Alarm
1500	Restore System Disable	Restoral, No Alarm
1501	Restore Access Reader Disable	Restoral, No Alarm
1502	Restore System Disable	Restoral, No Alarm
1503	Restore System Disable	Restoral, No Alarm
1504	Restore System Disable	Restoral, No Alarm
1505	Restore System Disable	Restoral, No Alarm
1506	Restore System Disable	Restoral, No Alarm
1507	Restore System Disable	Restoral, No Alarm
1508	Restore System Disable	Restoral, No Alarm
1509	Restore System Disable	Restoral, No Alarm
1510	Restore System Disable	Restoral, No Alarm
1520	Restore Sndr/Rly Disable	Restoral, No Alarm
1521	Restore Bell 1 Disable	Restoral, No Alarm
1522	Restore Bell 2 Disable	Restoral, No Alarm
1523	Restore Alrm Rly Disable	Restoral, No Alarm
1524	Restore Trbl Rly Disable	Restoral, No Alarm
1525	Restore RVSG Rly Disable	Restoral, No Alarm
1526	Restore Notif. Applnce CKT #3	Restoral, No Alarm
1527	Restore Notif. Applnce CKT#4	Restoral, No Alarm
1530	Restore Periphrl Disable	Restoral, No Alarm
1531	Restore Module Added Periphrl Disable	Restoral, No Alarm
1532	Restore Module Removed Perifphrl Disable	Restoral, No Alarm
1533	Restore Periphrl Disable	Restoral, No Alarm
1534	Restore Periphrl Disable	Restoral, No Alarm
1535	Restore Periphrl Disable	Restoral, No Alarm
1536	Restore Periphrl Disable	Restoral, No Alarm
1537	Restore Periphrl Disable	Restoral, No Alarm
1538	Restore Periphrl Disable	Restoral, No Alarm
1539	Restore Periphrl Disable	Restoral, No Alarm
1540	Restore Periphrl Disable	Restoral, No Alarm

1551	Restore Dialer Disable	Restoral, No Alarm
1552	Restore Radio TX Disable	Restoral, No Alarm
1553	Restore Remote Up/Dnw Disbl	Restoral, No Alarm
1570	Restore Zone Bypass	Restoral, No Alarm
1571	Restore Fire Bypass	Restoral, No Alarm
1572	Restore 24 Hour Zone Bypass	Restoral, No Alarm
1573	Restore Burglary Bypass	Restoral, No Alarm
1574	Restore Group Bypass	Restoral, No Alarm
1575	Restore Swinger Bypass	Restoral, No Alarm
1576	Restore Access Zone Shunt	Restoral, No Alarm
1577	Restore Access Pint Bypass	Restoral, No Alarm
1601	Restore Manual Test	Restoral, No Alarm
1602	Restore Periodic Test	Restoral, No Alarm
1603	Restore Periodic RF XMN	Restoral, No Alarm
1604	Restore Fire Test	Restoral, No Alarm
1605	Restore Status RPT Next	Restoral, No Alarm
1606	Restore Listen in next	Restoral, No Alarm
1607	Restore Walk Test Mode	Restoral, No Alarm
1608	Restore Sys Trbl PResent	Restoral, No Alarm
1609	Restore Video TX Active	Restoral, No Alarm
1611	Restore Point Tested OK	Restoral, No Alarm
1612	Restore Point not Tested	Restoral, No Alarm
1613	Restore Intrsn ZE Wlk Tested	Restoral, No Alarm
1614	Restore Fire ZN Walk Tested	Restoral, No Alarm
1615	Restore Panic ZN Walk Tested	Restoral, No Alarm
1616	Restore Service Request	Restoral, No Alarm
1621	Restore Event Log Reset	Restoral, No Alarm
1622	Restore Eventlg 50% Full	Restoral, No Alarm
1623	Restore Eventlg 90% Full	Restoral, No Alarm
1624	Restore Eventlg Overflow	Restoral, No Alarm
1625	Restore Time-Date Reset	Restoral, No Alarm
1626	Restore Time-Date Wrong	Restoral, No Alarm
1627	Restore Progr Mode Entry	Restoral, No Alarm
1628	Restore Progr Mode Exit	Restoral, No Alarm
1629	Restore 32HrR Evnt Log Mrkr	Restoral, No Alarm
1630	Restore Schedule Changed	Restoral, No Alarm
1631	Restore Exception Sched. Change	Restoral, No Alarm
1632	Restore Accss Schd Chnge	Restoral, No Alarm
1641	Restore Senior Wtch Trbl	Restoral, No Alarm
1642	Restore Latchkey Sprvsn	Restoral, No Alarm
1651	Restore Reserved Adempco	Restoral, No Alarm
1652	Restore Reserved Adempco	Restoral, No Alarm
1653	Restore Reserved Adempco	Restoral, No Alarm
1654	Restore System Inactivity	Restoral, No Alarm
1688	Restore Periodic test	Restoral, No Alarm
1689	Restore Raid Alarm	Restoral, No Alarm

