

Type Report

Report Date: 11/28/2019

RHWA000101 Rhino Watchguard

Type No	Description	Action Plan
120	PANIC	Medical Alarm
131	PERIMETER	General Alarm
132	INTERIOR	General Alarm
133	ALARM	General Alarm
137	CASE TAMPER	General Alarm
144	WIRELESS DEVICE TAMPER	General Alarm
300	SYSTEM COP RESET	System Alarm
301	MAINS POWER	Low Battery
302	SYSTEM LOW BATTERY	Low Battery
305	SYSTEM REBOOT	System Alarm
306	RP PROGRAMMING COMPLETE	System Alarm
308	SYSTEM SHUTDOWN	Low Battery
313	CODE (BUFFER) ERROR	System Alarm
333	SIREN RESET	System Alarm
338	WIRELESS SIREN BATTERY	Low Battery
339	REAL TIME CLOCK RESET	System Alarm
341	WIRELESS SIREN TAMPER	Low Battery
342	WIRELESS SIREN MAINS POWER	A/C Failure
343	REAL TIME CLOCK FAIL	System Alarm
344	JAMMING DETECTION	System Alarm
352	BILLING FAILED	System Alarm
353	BUSINESS PLAN ACTIVATION	A/C Failure
354	BUDGET PLAN ACTIVATION	A/C Failure
356	HOME PLAN ACTIVATION	A/C Failure
371	EXTERNAL TAMPER	System Alarm
381	WIRELESS SUPERVISION	Low Battery
384	WIRELESS LOW BATTERY	System Alarm
400	DISARMED	Opening (Unset), No Alarm
441	HOME MODE	Closing (Set), No Alarm
1120	PANIC	Restoral, No Alarm
1131	PERIMETER	Restoral, No Alarm
1132	INTERIOR	Restoral, No Alarm
1133	RESTORE	Restoral, No Alarm
1137	CASE TAMPER	Restoral, No Alarm
1144	WIRELESS DEVICE TAMPER	Restoral, No Alarm
1301	MAINS POWER	Restoral, No Alarm

1302	SYSTEM LOW BATTERY	Restoral, No Alarm
1308	SYSTEM SHUTDOWN	Restoral, No Alarm
1338	WIRELESS SIREN BATTERY	Restoral, No Alarm
1341	WIRELESS SIREN TAMPER	Restoral, No Alarm
1342	WIRELESS SIREN MAINS POWER	Restoral, No Alarm
1344	JAMMING DETECTION	Restoral, No Alarm
1351	TELCO FAIL RETRY LIMIT	A/C Failure
1352	BILLING SUCCESSFUL	System Alarm
1371	EXTERNAL TAMPER	Restoral, No Alarm
1381	WIRELESS SUPERVISION	Restoral, No Alarm
1384	WIRELESS LOW BATTERY	Restoral, No Alarm
1400	ARMED	Closing (Set), No Alarm
1602	PERIODIC TEST SIGNAL	System Alarm
1624	CID BUFFER OVERFLOW	System Alarm